

序号	监测时间	烟气流量- AVG (M3/s)	烟气流量- COU (M3)	二氧化硫- AVG (mg/m3)	二氧化硫- COU (kg)	S02折算浓- 度	氮氧化物- AVG (mg/m3)	氮氧化物- COU (kg)	NOX折算浓- 度	烟尘- AVG (mg/m3)	烟尘- COU (kg)	烟尘折- 算浓度	烟气温度- AVG (℃)	烟气压- 力	氧气含量- AVG (%)	烟气流- 速	烟气湿- 度
1	2023-07	57.508	15154570.3	2.126	288.24	1.638	254.416	38288.48	217.4	2.743	409.51	2.325	114.557	-0.54	8.054	17.157	9.538
2	2023-08	57.964	94156897.7	1.641	145.92	1.358	257.812	24422.69	220.252	3.137	294.15	2.663	115.928	-0.54	8.027	17.398	9.7
3	2023-09	65.628	111375953.7	0.597	66.74	0.5	279.221	31085.31	236.198	4.558	499.19	3.862	116.368	-0.527	7.941	19.845	9.764
4	个数	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
5	最小值	57.508	95156397.7	0.597	66.74	0.5	254.416	24422.69	217.4	2.743	294.15	2.325	114.557	-0.54	7.941	17.157	9.538
6	最大值	65.628	15154570.3	2.126	288.24	1.638	279.221	38288.48	236.198	4.558	499.19	3.862	116.368	-0.527	8.054	19.845	9.764
7	算术平均值	60.37	119326640.57	1.45	166.97	1.17	263.82	31265.49	224.62	3.48	400.95	2.95	115.62	-0.54	8.01	18.13	9.67
8	加权平均值	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9	合计	-	357979921.7	-	500.9	-	-	93796.48	-	-	1202.85	-	-	-	-	-	-

